

# Jharkhand State Electricity Board

331938

App. Sl. No. 212/CH-II Dated 26-09-07 App. Fee Depo. Rs. 2000 R. R. No. .... Dated 26-09-07  
07-08

Details Estimate for giving new Commercial Service Connection

To Sri. Sri Ananddeo Upadhyay S/o Sri Uma Nath Upadhyay At Gusyat colony  
Director of (T.V. T.G.) Chaj.

Load Twenty K.W. Transformer No. 01 Distance 10mts.

Sl. No.	ITEM	Quantity	Rate	Unit	Charable	
					Board	Party
1	2	3	4	5	6	7
1	T w Meter Board 12" x 18"	1 No.				
2	Kit Kat <del>10A</del> 100 Amp.	3 Nos.				
3	Service pipe $\phi$ 1 1/2" dia. 2mts.	1 No.				
4	PVC Wire <del>2.5mm</del> 10mm <sup>2</sup> S/core	64mts				
5	Meter 1x10A 3x20-100 Amp.	1 No.				
6	G I Wire WD B No-8 S.W.G.	1.5 Kg.				
	M.S. Nuts & Bolts.	2 Kg.				

except Energy meter all materials are supplied by the applicant.

General & Technical Report: → The capacity of the connected transformer on the transformer box is 12 KVA and the existing transformer is 200 KVA. and the existing at near Gusyat colony more in front of Shri. Sharmada Hall, so the above connection may be given.


Distance measurement & No. ques certification is given by Sri Jainendra Singh. (J.S.H.M.)

TOTAL Rs. as a labour cost, i.e. Rs. 3071-00 only

There is no ques against the applied premises or in the name of the applicant.

01-10-07  
 Addl. Asstt. Electric Engineer  
 Electric Supply Section  
 CHAS No. - 11

571/212/CH-II/07-08.  
 Labour Cost 3071-  
 Supervision Cost 117-  
 3071-  
 8000-  
 757-  
 Chargeable to Board Rs  
 Chargeable to Party Rs

  
 Asstt. Elect Engineer  
 Electric Supply Sub-division  
 11/10/07

Chargeable to Board Rs  
 Chargeable to Party Rs